

ਦਫਤਰ ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ, ਉਸਾਰੀ ਮੰਡਲ ਲੋ:ਨਿ:ਵਿ, ਭਵਨ ਤੇ ਮਾਰਗ ਸ਼ਾਖਾ, ਮਾਲੇਰਕੋਟਲਾ  
ਫੋਨ ਨੰਬਰ/ਫੈਕਸ ਨੰਬਰ-01675-253008 ਈਮੇਲ ਆਈ.ਡੀ [xenpwdmalerkotla@gmail.com](mailto:xenpwdmalerkotla@gmail.com)

ਵੱਲ

ਪ੍ਰਿੰਸੀਪਲ,  
ਸੰਪੂਰਨ ਪਬਲਿਕ ਸਕੂਲ,  
ਅਜੀਮਾਬਾਦ, ਮਤੋਈ, ਤਹਿਸੀਲ, ਮਾਲੇਰਕੋਟਲਾ,  
ਜਿਲ੍ਹਾ ਸੰਗਰੂਰ।

ਨੰਬਰ: 162

ਮਿਤੀ 11-04-2022

ਵਿਸ਼ਾ :- ਸਕੂਲ ਦੀ ਬਿਲਡਿੰਗ ਦਾ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਜਾਰੀ ਕਰਨ ਸਬੰਧੀ।  
(SAMPURAN PUBLIC SCHOOL, AZIMABAD, TEHSIL MALERKOTLA,  
DISTT SANGRUR)।

ਹਵਾਲਾ: ਆਪ ਦਾ ਪੱਤਰ ਮਿਤੀ 28.03.2022

ਉਪਰੋਕਤ ਵਿਸ਼ੇ ਸਬੰਧੀ ਲਿਖਿਆ ਜਾਂਦਾ ਹੈ ਕਿ ਇਸ ਮੰਡਲ ਦੇ ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ, ਉਸਾਰੀ ਉਪ ਮੰਡਲ ਨੰ:1, ਮਾਲੇਰਕੋਟਲਾ ਵੱਲੋਂ ਬਿਲਡਿੰਗ ਦਾ ਨਿਰੀਖਣ ਕਰਨ ਉਪਰੰਤ ਰਿਪੋਰਟ ਕੀਤੀ ਹੈ ਕਿ ਬਿਲਡਿੰਗ ਸਾਲ 2022-23 (31.03.2023) ਤੱਕ ਬਾਹਰੋਂ ਵੇਖਣ ਵਿੱਚ ਸੇਫ ਜਾਪਦੀ ਹੈ। ਇਸ ਤੋਂ ਇਲਾਵਾ ਇਹ ਵੀ ਲਿਖਿਆ ਜਾਂਦਾ ਹੈ ਕਿ ਬਿਲਡਿੰਗ ਵਿੱਚੋਂ ਜੇਕਰ ਕੋਈ ਵੀ ਅਡੀਸ਼ਨਲ ਆਲਟਰੇਸ਼ਨ ਕਰਨੀ ਹੈ ਤਾਂ ਕਿਸੇ ਟੈਕਨੀਕਲ ਕੁਆਲੀਫਾਈਡ ਇੰਜੀਨੀਅਰ ਪਾਸੋਂ ਚੈਕ ਕਰਵਾਕੇ ਤਸਦੀਕ ਕਰਵਾਇਆ ਜਾਵੇ ਜੇਕਰ ਹੜ੍ਹ, ਕੁਦਰਤੀ ਆਫਤ ਨਾਲ ਕੋਈ ਵੀ ਦੀਵਾਰ, ਨੀਹਾ ਬਹਿੰਦੀਆਂ ਹਨ ਤਾਂ ਉਸ ਬਾਰੇ ਵੀ ਟੈਕਨੀਕਲ ਕੁਆਲੀਫਾਈਡ ਇੰਜੀਨੀਅਰ ਪਾਸੋਂ ਚੈਕ ਕਰਾਉਣ ਉਪਰੰਤ ਤਸਦੀਕ ਵੀ ਕਰਵਾਇਆ ਜਾਵੇ। ਇਸ ਦੀ ਇੰਸਪੈਕਸ਼ਨ ਫੀਸ ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ, ਉਸਾਰੀ ਉਪ ਮੰਡਲ ਨੰ:1, ਮਾਲੇਰਕੋਟਲਾ ਵੱਲੋਂ ਜੀ.ਆਰ ਨੰਬਰ-664119 ਮਿਤੀ 04.04.2022 ਰਾਹੀਂ 10,000/- ਰੁਪਏ ਜਮ੍ਹਾਂ ਕਰਵਾ ਲਈ ਗਈ ਹੈ।

ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ,  
ਉਸਾਰੀ ਮੰਡਲ ਲੋਕ ਨਿਰਮਾਣ ਵਿਭਾਗ,  
ਭਵਨ ਤੇ ਮਾਰਗ ਸ਼ਾਖਾ, ਮਾਲੇਰਕੋਟਲਾ।

ਪਿੱਠ ਅੰਕਣ ਨੰਬਰ

ਮਿਤੀ

ਉਪਰੋਕਤ ਦਾ ਉਤਾਰਾ ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ, ਉਸਾਰੀ ਉਪ ਮੰਡਲ ਨੰ:1, ਮਾਲੇਰਕੋਟਲਾ ਨੂੰ ਉਨ੍ਹਾਂ ਦੇ ਪੱਤਰ ਨੰਬਰ:-02 ਮਿਤੀ: 04.04.2022 ਦੇ ਸਬੰਧ ਵਿੱਚ ਸੂਚਨਾ ਹਿੱਤ ਭੇਜਿਆ ਜਾਂਦਾ ਹੈ।

  
Principal  
Sampuran Public School  
Azimabad, Matol, Malerkotla  
148023 (Sangrur)  
(Affiliated to CBSE)

ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ,  
ਉਸਾਰੀ ਮੰਡਲ ਲੋਕ ਨਿਰਮਾਣ ਵਿਭਾਗ,  
ਭਵਨ ਤੇ ਮਾਰਗ ਸ਼ਾਖਾ, ਮਾਲੇਰਕੋਟਲਾ।



## Building safety report


Name of School:-Sampuran public School, Azimabad,(Distt. Malerkotla)

As per report of Sh. Charan Singh Assistant Engineer on his visually inspection, the above mentioned school seems visually safe subject to the following observations and conditions:-

1. However, the Parameters to check the stability and safety of building such as Architectural Drawings, Bearing capacity, Foundation details, Structural drawings, Technical Specifications, Test reports of Material used and Quality control reports are not available.
2. In case any addition, alteration, expansion and modification to this building are required to be done, regarding this inspection of undersigned may be arranged and obtained a certificate after the completion from the undersigned.
3. In the case of building is affected by flood or if there is any settlement of walls foundation of roof etc. immediately inspection of the undersigned be arranged to check the stability and safety of the building.
4. A separate certificate regarding Fire Fighting should be obtained from the competent Authority.
5. A separate certificate regarding Electrical works should be obtained be from the competent Authority.
6. The owner of the building/ Management is fully responsible regarding safety of the building from all angles in spite of this report.
7. This report is for the covered area of the building as per Drawing submitted by the owner.
8. This report is not valid for legal purpose.

As per visually inspection as reported by the concerned Assistant Engineer the above building may be used for normal use for One year up to 31/03/2023 subject to the above conditions.

  
Principal  
Sampuran Public School  
Azimabad, Matoi, Malerkotla  
148023 (Sangrur)  
(Affiliated to CBSE)

  
Sub-Divisional Engineer,  
Const. Sub Division no 1,  
PWD B&R Malerkotla.